

# ift-Nachweis



## Classification Report

Number	15-000659-PR07 (NW-A01-05-en-01)
Owner	ELVIAL S.A. Aluminium Extrusion 25th Km national road Thessaloniki 61100 Kilkis Greece
Product	single sash Tilt and Turn inwards opening door
Designation	System: Xclusive 85/86 Shipping name: Xclusive 85/86 single sash Tilt and Turn inwards opening door
Details	Material Aluminium; Attack side Closing face as per EN 12519; Type of opening Tilt and turn; Overall dimensions (W x H) 1000 mm x 2300 mm; Hardware: Manufacturer Winkhaus, - Königsberg; System ActivePilot; window handle HOPPE Secustik TDSs; Safety locking points 15 ; Air gap restrictor 4 ; LSG: Note Class: P6B according to EN 356
Special features	

### Result

Burglary resistance according to EN 1627:2011-05



**Class: RC 2 / RC 2N**

### Basis \*)

EN 1627:2011-05

\*) and corresponding national versions  
e.g. DIN EN)

Test report: 15-000659-PR07 PB-A01-05-en-01

### Representation



### Instructions for use

The results obtained apply to the field of extended application as set out in EN 1627, Annex D.

### Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

12.09.2018

Konrad Querengässer, Dipl.-Ing. (FH)  
Head of Testing Department  
Security/Safety Testing

Fabian Kutscher, Dipl.-Ing. (FH)  
Operating Testing Officer  
Security/Safety Testing

Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: F06-F048E